




**INDICATIVE WATER BALANCE
AND BLOC DIAGRAM**

APPENDIX

6

APPENDIX 6: Indicative Water Balance and Bloc Diagram



Figures are in t/h

Preliminary

Operating condition
 - Normal operation at load point:
 - No. of Lines in operation:
 - Rain water not considered


LP N
1

Design Data
 Thermal power waste per line 101.8 MW
 Waste throughput per line 37.5 t/h
 Ash content waste 23.0%
 Flue gas temp. inlet FGT 135 °C

Remarks
 - The purpose of this mass balance calculation is to determine the overall process water consumption of the plant. It does not show all internal connections.
 - The unit of all values is t/h (1'000 kg/h) except indicated otherwise.
 - All given values are expected/assumed operating values and are given as mean values over the operation period.
 - Water steam cycle losses are counted fully as losses despite partly being recovered in bottom ash and/or process water basin.
 - The given values shall not be used for pipe sizing purposes since it may not correspond to the design value of it.
 - The calculation of cooling water flow for boiler blowdown is based on the following assumptions:
 Temperature of cooling water: 20 °C
 Temperature of after cooling: 100 °C

Mass Balance, status: i.o.
 - Total water input 6.17 t/h
 - Total water output 6.17 t/h

2			
1			
0	25.08.17	First Issue	
Rev.	Date	Description	
Project Name		Project No	Load point
Rockingham		YE-3324	LP N
Date		Name	Hitachi Zosen INOVA
Prepared	25.08.17	Rem	
Checked			
Approved			
Prog. No. : CSP-104 / V4.5		Water Balance - Process	
		Bloc Diagram	
		HZI doc. N° :	Revision
		-	1
		Print date : 25.08.17	Page : 1/1



Flue gas data:		1	2
Composition and Emission		Boiler exit	clean gas
Flow rate	Nm ³ /h	195'393	162'299
Density	kg/Nm ³	1.25	1.25
Temperature	(3) °C	135	135
Composition			
H ₂ O	Vol%	19.6	19.5
O ₂	Vol%	4.3	4.4
N ₂	Vol%	64.7	64.9
CO ₂	Vol%	11.3	11.2
Others	Vol%	0.1	0.0
Total	Vol%	100.0	100.0
Content of emission			
Emissions referring to dry gas at 11%O ₂ at reference conditions			
Flow rate	11%O ₂ , dry Nm ³ /h	246'045	246'045
Dust	mg/Nm ³	1829	2
CO	mg/Nm ³	20	20
TOC	mg/Nm ³	2	2
NO _x	mg/Nm ³	185	185
HCl	mg/Nm ³	800	9
SO ₂	mg/Nm ³	250	20
HF	mg/Nm ³	10	0.1
NH ₃	mg/Nm ³	2	2
Heavy metals			
Hg	mg/Nm ³	0.2	<0.01
Cd+Tl	mg/Nm ³	2	<0.02
Sb+As+Pb+Cr+Co	mg/Nm ³	50	<0.2
+Cu+Mn+Ni+V	ng/Nm ³	2	<0.05
Dioxins / furans - TEQ			
	ng/Nm ³	2	<0.05

Remarks
 Indicated values are expected average operating values and not guarantee values
 The Reference Condition for gas volumes (described as Nm³) is: 0.0 °C / 1013.25 mbar
 Air density: 1.279 kg/Nm³
 (1) Steam parameters: 61.5 bara 421 °C
 (2) Feedwater temperature: 120 °C
 (3) Based on marginal boiler fouling (approx. 800 operating hours)

Indicated values taken from the following design calculations:

Prog. No.	Doc. No.	Rev.	Date
CSP-005	N/A	0	23.08.2017
-	N/A	0	xx.xx.xxxx
-	N/A	0	xx.xx.xxxx
-	N/A	0	xx.xx.xxxx

Rev.	Date	Description
1	31.08.17	Residue moistening included
0	25.08.17	First Issue

Project Name	Project No	Load point	Hitachi Zosen INOVA
Rockingham	YE-3324	LPN	
Date	Name	BLOC DIAGRAM	
23.08.2017	strobil / Kas		
Prepared			
Checked		HZI doc. N°:	Revision
Approved		-	1